



Test Report issued under the responsibility of:

TEST REPORT

EN 60 947-6-1

Low-voltage switchgear and controlgear

Part 6-1: Multiple function equipment - Transfer switching equipment

Report Reference No.: 03601-A-14D0070-S

Date of issue: 2015-02-10

Total number of pages: 33

CB Testing Laboratory: Suzhou Electrical Apparatus Science Research Institute Stock Co., Ltd.

Address: No.7 Yonghe Street, Binghe Road, New District, Suzhou

Applicant's name: Suzhou Feiteng Appliance Co., Ltd.

Address: Yongwu Road, Lingfeng Village, Beiqiao Town, Xiangcheng District, Suzhou City

Test specification:

Standard: ☒ EN60 947-6-1:2005 with

☒ EN60947-1:2004

Test procedure: CCA

Non-standard test method: N/A

Test Report Form No.: EN60947_6_1A

Test Report Form(s) Originator: CQC-TILVA

Master TRF: Dated 2013-01

Copyright © 2008 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

Test item description: AUTOMATIC TRANSFER SWITCH EQUIPMENT

Trade Mark: N/A

Manufacturer: Suzhou Feiteng Appliance Co., Ltd.

Model/Type reference: W2H-125A 2F, W2H-125A 2B, W2H-125A 3F, W2H-125A 3B, W2H-125A 4F, W2H-125A 4B

Ratings: Ue: AC400V; Ui: 690V;
Ith: 125A; Ie: 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A;
AC-33iA; Iq: 100kA;
ATSE; PC: 2P, 3P, 4P.

Testing procedure and testing location:	
☒ CB Testing Laboratory:	Suzhou Electrical Apparatus Science Research Institute Stock Co., Ltd. (EET)
Testing location/ address.....:	No.7 Yonghe Street, Binhe Road, New District, Suzhou, China
☐ Associated CB Laboratory:	
Testing location/ address.....:	
Tested by (name + signature).....:	Dai Weiqiang
Approved by (+ signature)	Hu Delin
☐ Testing procedure: TMP	
Tested by (name + signature).....:	
Approved by (+ signature)	
Testing location/ address.....:	
☐ Testing procedure: WMT	
Tested by (name + signature).....:	
Witnessed by (+ signature).....:	
Approved by (+ signature)	
Testing location/ address.....:	
☐ Testing procedure: SMT	
Tested by (name + signature).....:	
Approved by (+ signature)	
Supervised by (+ signature).....:	
Testing location/ address.....:	
☐ Testing procedure: RMT	
Tested by (name + signature).....:	
Approved by (+ signature)	
Supervised by (+ signature).....:	
Testing location/ address.....:	




戴维强
胡德霖

Summary of testing:**Tests performed (name of test and test clause):**


Test sequence I : W2H-125A 4F 125A
 W2H-125A 2F 125A
 Test sequence II : W2H-125A 4F 125A
 W2H-125A 2F 125A
 Test sequence III: W2H-125A 4F 16A
 W2H-125A 2F 16A
 Test sequence IV: W2H-125A 4F 125A

Testing location:

No.7 Yonghe Street, Binhe Road, New District,
 Suzhou, China

Summary of compliance with National Differences: N/A**Copy of marking plate**

Copy of marking plate



Type: W2H-125A 4F

Rated working voltage	400V AC	Rated working current	125A
Insulation voltage	690V AC	Impact-resistant voltage	8kV
Use class	PC	Utilization category	AC-331A
Frequency	~50Hz	Date	
Standard	EN60947-6-1 GB/T14048.11		
Rated short-circuit current limit (RT16-00-125A)	100kA		

Suzhou Feiteng Appliance CO., LTD

Test item particulars.....	
Type of equipment	ATSE
-class of equipment.....	PC
-method of controlling	ATSE
-number of poles	2P,3P,4P
-kind of current	AC
-operating sequence	I - II / II - I
-pollution degree	3
-EMC environment	B
Rated voltages	AC400
-rated operational voltage U_e (V).....	AC400
-rated insulation voltage U_i (V).....	690
-rated impulse withstand voltage U_{imp} (kV).....	8
Conventional free air thermal current I_{th} (A)	125
Conventional enclosed thermal current I_{the} (A)	N/A
Rated operational current I_e (A)	16,20,25,32,40,50,63,80,100,125
Rated frequency (Hz)	50
Uninterrupted duty	N/A
Utilization category	AC-33iA
Short-circuit characteristic.....	
-rated short-time withstand current I_{cw} (kA).....	N/A
-rated short-circuit making capacity I_{cm} (kA)	N/A
-rated short-circuit breaking capacity I_{cn} (kA)	N/A
-rated conditional short-circuit current (kA)	100kA
Control circuits.....	220
-kind of current	AC
-rated frequency (Hz)	50
-rated control circuit voltage U_c (V)	N/A
-rated control supply voltage U_s (V)	220
Transfer control devices	N/A
-monitored supply deviation of ATSE	85~110% U_e
-voltage deviation	85~110% U_e
-frequency deviation	N/A
-contact transfer time (ms).....	<1s
-operating transfer time (ms)	<1s

-total operating time (ms).....: N/A
 -return transfer time (ms).....: <1s
 -off time (ms).....: <100ms(Delay time 0s-250s)

Auxiliary circuits.....: N/A
 -rated operational voltage (V).....: N/A
 -rated frequency (Hz).....: N/A
 -number of circuits.....: N/A
 -number and kind of contact elements.....: N/A

Possible test case verdicts:

- test case does not apply to the test object.....: N/A
 - test object does meet the requirement.....: P (Pass)
 - test object does not meet the requirement.....: F (Fail)

Testing.....:

Date of receipt of test item.....: 2014-01-14, 2014-02-18, 2015-01-22

Date (s) of performance of tests.....: 2014-01-18~2014-01-29,2014-02-21~2014-02-27

General remarks:

The test results presented in this report relate only to the object tested.
 This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.
 "(See Enclosure #)" refers to additional information appended to the report.
 "(See appended table)" refers to a table appended to the report.

Throughout this report a comma (point) is used as the decimal separator.

General product information:

W 2 H - 125A ☐ ☐

Wiring mode: F- Board front wiring
 B- Board behind wiring
 Number of poles: 2-two poles 3-three poles
 4-four poles
 Frame current 125A
 H type
 Two stage
 Product codes and meaning

EN 60 947-6-1

Clause	Requirement + Test	Result - Remark	Verdict
6.2	MARKING		
	Marking on equipment itself or on nameplate or nameplates attached to the equipment and legible when the equipment is installed		P
	-manufacturer's name or trademark..... : Suzhou Feiteng Appliance Co.,Ltd.		P
	-type designation or serial number : W2H-125A 4F		P
	-class of equipment..... : PC		P
	-rated operational voltage : AC400V		P
	-rated operational current..... : 125A		P
	-utilization category : AC-33iA		P
	-rated frequency : 50Hz		P
	-rated short-circuit making capacity for class PC/CC:		N/A
	-rated short-circuit withstand current and duration.. :		N/A
	-rated impulse withstand voltage : 8kV		P
	Data which may be marked on the equipment and shall given in the manufacturer's literature		
	-number of main contact positions : 4		P
	-monitored supply deviation and operating limits : 85~110%Ue		P
	-operating sequence and time delays..... : 0s~250s		P
	-environment A or B : B		P
	.-off-time for derived TSE..... : <100ms(Delay time 0s-250s)		P
8.1	CONSTRUCTIONAL REQUIREMENTS		
8.1.1.1	Resistance to abnormal heat and fire		P
	Glow-wire test according to IEC 60695-2-10 and IEC 60695-2-11		—
	Parts made of insulating material necessary to retain current-carrying parts in position: test temperature 950 °C		P
	No visible flame and no sustained glowing		P
	Flames and glowing extinguish within 30 s		N/A
	No ignition of the tissue paper		N/A
	Parts of insulating material not necessary to retain current-carrying parts in position, even though in contact with them: test temperature 650 °C		N/A
	No visible flame and no sustained glowing		N/A
	Flames and glowing extinguish within 30 s		N/A
	No ignition of the tissue paper		N/A

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
7.1.2 of Part 1	Current-carrying parts and their connection		P
7.1.3 of Part 3	Clearances		P
	Creepage distances		P
	Pollution degree	3	—
	Comparative tracking index (V)	600	—
	Material group	I	—
7.1.4 of Part 3	Actuator		N/A
7.1.4.1 of Part 1	Insulation		N/A
	Actuator insulated from live parts for		—
	-rated insulation voltage		N/A
	-rated impulse withstand voltage		N/A
	Actuator made of metal		N/A
	- connected to a protective conductor or provided with an additional insulation		N/A
	Actuator made of or covered by insulating material :		N/A
	- internal metal parts, which might become accessible in the event of an insulation failure, are also insulated from live parts for the rated insulation voltage		N/A
7.1.4.2 of Part 1	Direction of movement		N/A
	The direction of operation for actuators shall where applicable conform to IEC 60447		N/A
	There is no doubt of the "I" and "O" position and the direction of operation		N/A
7.1.5 of Part 1	Indication of contact position		N/A
7.1.5.1 of Part 1	Indicating means		N/A
7.1.5.2 of Part 1	Indication by the actuator		N/A
7.1.6 of Part 1	Additional safety requirements for equipment suitable for isolation		N/A
7.1.6.1 of Part 1	Additional constructional requirements for equipment suitable for isolation ($U_e > 50 \text{ V}$)		N/A

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	-marking according to 5.2.1b of part 3		N/A
	-indication of the position of the contacts		N/A
	-construction of the actuating mechanism		N/A
	-minimum clearances across open contacts (see Table XII, Part 1) (mm)		—
	-measured clearances (mm)		N/A
	-test Uimp across gap (kV)		N/A
7.1.6.2 of Part 1	Supplementary requirements for equipment with provision for electrical interlocking with contactors or circuit-breakers		N/A
	Auxiliary switch is rated according to IEC 60947-5 (unless the equipment is rated AC-23)		N/A
	Time interval between opening of the contacts of the auxiliary contact and the contacts of the main poles: ≥ 20 ms		—
	Measured time interval (ms)		N/A
	During the closing operation the contacts of the auxiliary switch closes after or simultaneously with the contacts of the main poles		N/A
7.1.6.3 of Part 1	Supplementary requirements for equipment provided with means for padlocking the open position:		N/A
	The locking means is so designed that it cannot be removed with the appropriate padlock(s) installed		N/A
	Test force F applied to the actuator in an attempt to operate to the closed position (N)		—
	Rated impulse withstand voltage (kV)		—
	Test Uimp on open main contacts at the test force		N/A
7.1.7 of Part 1	Terminals		P
7.1.7.1 of Part 1	All parts of terminals which maintain contact and carry current are of metal having adequate mechanical strength		P
	Terminal connections are such that necessary contact pressure is maintained		P
	Terminals are so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal		P
	Terminals do not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage is not reduced below the rated value		P

CE TEST REPORT

Application No.: CE2014CQC0304-006946

Report Ref. No.: 03601-A-14D0070-S

Name of product: **AUTOMATIC TRANSFER SWITCH
EQUIPMENT**

Model: W2H-125A 2F, W2H-125A 2B, W2H-125A 3F,
W2H-125A 3B, W2H-125A 4F, W2H-125A 4B

Name of Laboratory: **Suzhou Electrical Apparatus
Science Research Institute Stock
Co., Ltd.**



CHINA QUALITY CERTIFICATION CENTRE

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.4 of Part 1	Mechanical properties of terminals		P
	Mechanical strength of terminals		P
	Maximum cross-sectional area of conductor (mm ²) :	50	—
	Diameter of thread (mm)	M8	—
	Torque (Nm)	6.0	—
	5 times on 2 separate clamping units		P
	Testing for damage to and accidental loosening of conductor (flexion test)		N/A
	Conductor of the smallest cross-sectional area (mm ²)		—
	Number of conductor of the smallest cross section :		—
	Diameter of bushing hole (mm)		—
	Height between the equipment and the platen		—
	Mass at the conductor(s) (kg)		—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		N/A
	Pull-out test		N/A
	Force (N), applied for 1 min.		—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		N/A
	Conductor of the largest cross-sectional area (mm ²)		—
	Number of conductor of the largest cross section :		—
	Diameter of bushing hole (mm)		—
	Height between the equipment and the platen		—
	Mass at the conductor(s) (kg)		—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		N/A
	Pull-out test		N/A
	Force (N), applied for 1 min.		—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		N/A
	Conductor of the largest and smallest cross-sectional area (mm ²)		—

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Number of conductor of the smallest cross section, number of conductor of the largest cross section .. :		—
	Diameter of bushing hole (mm)		—
	Height between the equipment and the platen		—
	Mass at the conductor(s) (kg)		—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		N/A
	Pull-out test		N/A
	Force (N), applied for 1 min. :		—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		N/A
7.1.7.2 of Part 1	Connection capacity		N/A
	Type of conductors	rigid	—
	Minimum cross-sectional area of conductor (mm ²) :		—
	Maximum cross-sectional area of conductor (mm ²) :	50	—
	Number of conductors simultaneously connectable to the terminal	1	—
7.1.7.3 of Part 1	Connection		P
	Terminals for connection to external conductors are readily accessible during installation		P
	Clamping screws and nuts do not serve to fix any other component		P
7.1.7.4 of Part 1	Terminal identification and marking		P
	Terminal intended exclusively for the neutral conductor		P
	Protective earth terminal		N/A
	Other terminals		N/A
7.1.8 of Part 1	Additional requirements for equipment provided with a neutral pole		P
	Equipment provided with a pole intended for the connection of neutral, this pole shall be clearly marked by the letter "N"		N/A
	The switched neutral pole does not break before and does not make after the other poles except		N/A

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- a pole having the appropriate short-circuit breaking and making capacity is used as neutral pole, all poles may operate together		N/A
	Conventional thermal current of neutral pole		N/A
7.1.9 of Part 1	Provisions for protective earthing		N/A
7.1.9.1 of Part 1	The exposed conductive parts are electrically interconnected and connected to a protective earth terminal		N/A
7.1.9.2 of Part 1	Protective earth terminal is readily accessible		N/A
	Protective earth terminal is suitably protected against corrosion		N/A
	Electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N/A
	Protective earth terminal has no other functions		N/A
7.1.9.3 of Part 1	Protective earth terminal marking and identification		N/A
7.1.10 of Part 1	Enclosure for equipment		N/A
7.1.10.1 of Part 1	Design		N/A
	When the enclosure is opened, all parts requiring access for installation and maintenance are readily accessible		N/A
	Sufficient space is provided inside the enclosure		N/A
	The fixed parts of a metal enclosure are electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N/A
	Under no circumstances a removable metal part of the enclosure is insulated from the part carrying the earth terminal when the removable part is in place		N/A
	The removable parts of the enclosure are firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N/A
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means is provided to prevent loss of the fastening devices		N/A

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	If the enclosure is used for mounting push-buttons, it is not possible to remove the buttons from the outside of the enclosure		N/A
7.1.10.2 of Part 1	Insulation		N/A
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining is securely fixed to the enclosure		N/A
7.1.11 of Part 1	Degree of protection of enclosed equipment		N/A
	Degree of protection : IP		N/A
9.3.3	TEST SEQUENCE I: PERFORMANCE UNDER NO-LOAD, NORMAL LOAD AND OVERLOAD CONDITION		P
9.3.3.1	Operation of the operating mechanism		P
	The equipment is capable of operating for all conditions of its marked intended performance		P
	The operating mechanism prevents simultaneous connection to both normal and alternative supplies		P
9.3.3.2	Controls, sequence and limits of operation		P
9.3.3.2.2	Overvoltage condition		P
9.3.3.2.3	Undervoltage condition of electromagnetic voltage sensing relays		N/A
9.3.3.2.4	Operation on loss of supply voltage	Table 1	P
9.3.3.2.5	Operation on reduction of supply voltage	Table 2	P
9.3.3.2.6	Transfer on availability of alternative voltage	Table 3	P
9.3.3.3	Temperature-rise		
	ambient temperature 10 – 40 °C : 17		—
	test enclosure W x H x D (mm x mm x mm) :		—
	material of enclosure..... :		—
	Main circuits, test conditions:		
	-conventional thermal current I _{th} (A) : 125		—
	-conventional enclosed thermal current I _{the} (A) :		N/A
	-cable / busbar cross-section (mm ²) / length (mm) .. : 50/2000		—
	Fuse-link details (fuse-combination units only):		N/A
	-manufacturer's name, trademark or identification mark : Suzhou Feiteng Appliance Co.,Ltd.		—

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	-manufacturer's model or type reference	W2H-125A 4F	—
	-rated current (A)	125	—
	-power loss (W)	N/A	—
	-rated breaking capacity (kA)	N/A	—
	Measured temperature-rise	Table 4	P
	Auxiliary circuits, test conditions:		N/A
	-rated operation current (A)		—
	-cable cross-section (mm ²)		—
	Measured temperature-rise Max. K		N/A
9.3.3.4	Dielectric properties		
	-rated impulse withstand voltage (kV)	8	—
	-test Uimp main circuits (kV)	9.8	P
	-test Uimp auxiliary circuits (kV)	4.8	P
	-test Uimp on open main contacts (equipment suitable for isolating) (kV)		N/A
	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):		
	-rated insulation voltage Ui (V)	690	—
	-main circuits, test voltage for 1 min. (V)	1890	P
	-control and auxiliary circuits, test voltage for 1 min. (V)	1500	P
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		N/A
	:Test voltage $1,1 \times 415 U_e$ (V)		—
	Measured leakage current (mA)		N/A
9.3.3	TEST SEQUENCE I: PERFORMANCE UNDER NO-LOAD, NORMAL LOUD AND OVERLOUD CONDITION		P
9.3.3.1	Operation of the operating mechanism		P
	The equipment is capable of operating for all conditions of its marked intended performance		P
	The operating mechanism prevents simultaneous connection to both normal and alternative supplies		P
9.3.3.2	Controls, sequence and limits of operation		P
9.3.3.2.2	Overvoltage condition		P
9.3.3.2.3	Undervoltage condition of electromagnetic voltage sensing relays		N/A
9.3.3.2.4	Operation on loss of supply voltage	Table 5	P

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.3.3.2.5	Operation on reduction of supply voltage	Table 6	P
9.3.3.2.6	Transfer on availability of alternative voltage	Table 7	P
9.3.3.3	Temperature-rise		
	ambient temperature 10 – 40 °C	17	—
	test enclosure W x H x D (mm x mm x mm)		—
	material of enclosure.....		—
	Main circuits, test conditions:		
	-conventional thermal current Ith (A)	125	—
	-conventional enclosed thermal current Ithe (A)		—
	-cable / busbar cross-section (mm ²) / length (mm) ..	50/2000	—
	Fuse-link details (fuse-combination units only):		N/A
	-manufacturer's name, trademark or identification mark	Suzhou Feiteng Appliance Co.,Ltd.	—
	-manufacturer's model or type reference	W2H-125A 2F	—
	-rated current (A).....	125	—
	-power loss (W).....	N/A	—
	-rated breaking capacity (kA).....	N/A	—
	Measured temperature-rise	Table 8	P
	Auxiliary circuits, test conditions:		N/A
	-rated operation current (A)		—
	-cable cross-section (mm ²)		—
	Measured temperature-rise Max. K.....		N/A
9.3.3.4	Dielectric properties		
	-rated impulse withstand voltage (kV)	8	—
	-test Uimp main circuits (kV)	9.8	P
	-test Uimp auxiliary circuits (kV)	4.8	P
	-test Uimp on open main contacts (equipment suitable for isolating) (kV)		N/A
	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):		
	-rated insulation voltage Ui (V).....	690	—
	-main circuits, test voltage for 1 min. (V).....	1890	P
	-control and auxiliary circuits, test voltage for 1 min. (V).....	1500	P
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		N/A
	:Test voltage 1,1 Ue (V)		—

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Measured leakage current (mA)	125	N/A
	TEST SEQUENCE II: OPERATING PERFORMANCE		
9.3.3.5	Making and breaking capacities		P
	-utilization category	AC-33iA	—
	-rated operational voltage U_e (V)	400	—
	-rated operational current I_e (A)	125	—
	Test conditions, make/break operations		
	-test voltage, $U = 1,05 \times U_e$ (V)	427	—
	-test current, $I = 6 \times I_e$ (A)	770	—
	-power factor	0.53	—
	-transient recovery voltage (V)		P
	-current duration (ms)	261	—
	-time interval between operation (s)	60	—
	Number of make/break operations	50	—
	Number of make/break operations with both supplies operated simultaneously	10	P
	-measured transfer time (ms)	126	—
	-measured time delay (ms)	0	—
	-measured off-time (ms)	68	—
	Characteristic of transient recovery voltage		
	-oscillatory frequency (kHz)		—
	-measured oscillatory frequency (kHz)		N/A
	-factor γ		N/A
9.3.3.5.4	Behaviour of the equipment during making and breaking capacity tests		P
9.3.3.5.4	Condition of the equipment after making and breaking capacity tests		P
9.3.3.6	Operational performance capability		P
	utilization category	AC-33iA	—
	rated operational voltage U_e (V)	400	—

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	rated operational current I_e (A).....:	125	—
9.3.3.6.2	Test conditions electrical performance cycles	427	P
	-test voltage, $U = 1,05 \times U_e$ (V).....:	427/427	—
	-test current, $I = 1 \times I_e$ (A) / $2 \times I_e$ (A).....:	127/256	—
	-power factor.....:	0.83/0.83	—
	Number of cycles with current.....:	3000/3000	P
	Duration of operating cycles.....:	1min	P
9.3.3.6.2	Behaviour of the equipment during operational performance tests		P
	Condition of the equipment after operational performance tests		P
9.3.3.4	Dielectric verification		
	test voltage ($2 \times U_e$) for 1min (V) (min.1000V).....:	1000V	—
	No breakdown or flashover		P
9.3.3.4	Leakage current		N/A
	test voltage ($1,1 \times U_e$) (V).....:		—
	Leakage current ≤ 2 mA / pole.....:		N/A
9.3.3.3 of Part 1	Temperature-rise verification		
	-conductor cross-section (mm^2)	50	—
	-test current I_e (A)	125	—
	Temperature-rise of main circuit terminals Max. 80 K	22	P
		20	P
9.3.3.6.3	Test conditions mechanical performance cycles		N/A
	Number of cycles without current.....:		N/A
	Duration of operating cycles.....:		N/A
9.3.3.6.3	Condition of the equipment after mechanical performance tests		N/A
9.3.3.2.4	Operation on loss of power supply voltage.....:		N/A
	Measured transfer time (ms).....:		N/A
	TEST SEQUENCE II: OPERATING PERFORMANCE		
9.3.3.5	Making and breaking capacities		P
	-utilization category.....:	AC-33iA	—
	-rated operational voltage U_e (V).....:	400	—
	-rated operational current I_e (A).....:	125	—

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test conditions, make/break operations		
	-test voltage, $U = 1,05 \times U_e$ (V)	427	—
	-test current, $I = 6 \times I_e$ (A)	770	—
	-power factor	0.53	—
	-transient recovery voltage (V)		P
	-current duration (ms)	260	—
	-time interval between operation (s)	60	—
	Number of make/break operations.....	50	—
	Number of make/break operations with both supplies operated simultaneously	10	P
	-measured transfer time (ms)	109	—
	-measured time delay (ms)	0	—
	-measured off-time (ms)	63	—
	Characteristic of transient recovery voltage		P
	-oscillatory frequency (kHz)		
	-measured oscillatory frequency (kHz)		N/A
	-factor γ		N/A
9.3.3.5.4	Behaviour of the equipment during making and breaking capacity tests		P
9.3.3.5.4	Condition of the equipment after making and breaking capacity tests		P
9.3.3.6	Operational performance capability		P
	utilization category.....	AC-33iA	—
	rated operational voltage U_e (V).....	400	—
	rated operational current I_e (A).....	125	—
9.3.3.6.2	Test conditions electrical performance cycles		P
	-test voltage, $U = 1,05 \times U_e$ (V)	427/427	—
	-test current, $I = 1 \times I_e$ (A) / $2 \times I_e$ (A)	127/256	—
	-power factor	0.83/0.83	—
	Number of cycles with current	3000/3000	P
	Duration of operating cycles	1min	P

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.3.3.6.2	Behaviour of the equipment during operational performance tests		P
	Condition of the equipment after operational performance tests		P
9.3.3.4	Dielectric verification		
	test voltage (2 x Ue) for 1min (V) (min. 1000V)	1000V	—
	No breakdown or flashover		P
9.3.3.4	Leakage current		N/A
	test voltage (1,1 x Ue) (V)		—
	Leakage current ≤ 2 mA / pole		N/A
9.3.3.3 of Part 1	Temperature-rise verification		
	-conductor cross-section (mm ²)	50	—
	-test current Ie (A)	125	—
	Temperature-rise of main circuit terminals Max. 80 K	19	P
		17	P
9.3.3.6.3	Test conditions mechanical performance cycles		N/A
	Number of cycles without current		N/A
	Duration of operating cycles		N/A
9.3.3.6.3	Condition of the equipment after mechanical performance tests		N/A
9.3.3.2.4	Operation on loss of power supply voltage.....		N/A
	Measured transfer time (ms)		N/A

	TEST SEQUENCE III: VERIFICATION OF SHORT CIRCUIT CAPABILITIES		
9.3.4	Performance under short circuit conditions		P
9.3.4.2.2	Short-circuit making capacity	(Circuit diagram No)	N/A
	Rated short-circuit making capacity Icm (kA)		N/A
	-test voltage (V)		N/A
	-r.m.s test current (kA)		N/A

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	-power factor		N/A
	-current duration (s)		N/A
	Maximum peak test current (kA)		N/A
	Time interval between the cycles.....		N/A
	Behaviour of the equipment during the test		N/A
9.3.4.3 c)	Conditions of the equipment after the test		N/A
9.3.3.4	Dielectric verification		N/A
	test voltage (2 x Ue) for 1min (V) (min.1000V)		N/A
	No breakdown or flashover		N/A
9.3.3.4	Leakage current		N/A
	test voltage (1,1 x Ue) (V)		N/A
	Leakage current ≤ 2 mA / pole		N/A
9.3.3.3 of Part 1	Temperature-rise verification		N/A
	-conductor cross-section (mm ²)		N/A
	-test current Ie (A)		N/A
	Temperature-rise of main circuit terminals Max. K:		N/A
9.3.4.2.3	Short-circuit breaking capacity		N/A
	Rated short-circuit breaking capacity Icn (kA)		N/A
	-test voltage (V).....		N/A
	-r.m.s test current (kA)		N/A
	-power factor		N/A
	-current duration (s)		N/A
	Maximum peak test current (kA)		N/A

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Time interval between the cycles..... :		N/A
	Behaviour of the equipment during the test		N/A
9.3.4.3 c)	Conditions of the equipment after the test		N/A
9.3.3.4	Dielectric verification		N/A
	test voltage (2 x Ue) for 1min (V) (min.1000V) :		N/A
	No breakdown or flashover		N/A
9.3.3.4	Leakage current		N/A
	test voltage (1,1 x Ue) (V) :		N/A
	Leakage current ≤ 2 mA / pole :		N/A
9.3.3.3 of Part 1	Temperature-rise verification		N/A
	-conductor cross-section (mm ²)		N/A
	-test current Ie (A)		N/A
	Temperature-rise of main circuit terminals. Max. K :		N/A
9.3.4.3	Short-time withstand current (Circuit diagram No)		N/A
	Rated short-time withstand current Icw (kA) :		N/A
	-test voltage (V)..... :		N/A
	-r.m.s test current (kA) :		N/A
	-peak test current (kA) :		N/A
	-power factor :		N/A
	-current duration (s) :		N/A
	Behaviour of the equipment during the test		N/A
9.3.4.3 c)	Conditions of the equipment after the test		N/A
9.3.3.4	Dielectric verification		N/A

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	test voltage (2 x Ue) for 1min (V) (min.1000V)	1000	N/A
	No breakdown or flashover		N/A
9.3.3.4	Leakage current		N/A
	test voltage (1,1 x Ue) (V)		N/A
	Leakage current ≤ 2 mA / pole		N/A
9.3.3.3 of Part 1	Temperature-rise verification		N/A
	-conductor cross-section (mm ²)		N/A
	-test current I _e (A)		N/A
	Temperature-rise of main circuit terminals . Max. K:		N/A
			N/A
9.3.4.4	Conditional short-circuit current (Circuit diagram No)		P
	Short-circuit protective device (SCPD) details		
	-manufacturer's name, trademark or identification mark	Suzhou Feiteng Appliance Co., Ltd.	—
	-manufacturer's model or type reference	W2H-125 4F	—
	-rated voltage (V)	400	—
	-rated current (A)	16	—
	-rated breaking capacity (kA)	100	—
	SCPD protective short-circuit		P
	-test voltage (V)	429	—
	-r.m.s test current (kA)	102	—
	-power factor	0.18	—
	SCPD protective short-circuit withstand		P
	-max. let-through current (kA)	3.450	—
	-joule integral I ² dt (kA ² s)	16.19	—
	SCPD protective short-circuit making		P
	-max. let-through current (kA)	3.426	—

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	-joule integral $i^2 dt$ (kA ² s)..... :	10.00	—
	Behaviour of the equipment during the test		P
9.3.4.3 c)	Conditions of the equipment after the test		P
9.3.3.4	Dielectric verification		P
	test voltage (2 x Ue) for 1min (V) (min. 1000V) :	1000	—
	No breakdown or flashover		P
9.3.3.4	Leakage current		N/A
	test voltage (1,1 x Ue) (V) :		—
	Leakage current ≤ 2 mA / pole :		N/A
9.3.3.3 of Part 1	Temperature-rise verification		P
	-conductor cross-section (mm ²)	50	—
	-test current I_e (A)	125	—
	Temperature-rise of main circuit terminals Max. K	19	P
9.3.4.4	Conditional short-circuit current (Circuit diagram No)		P
	Short-circuit protective device (SCPD) details		
	-manufacturer's name, trademark or identification mark :	Suzhou Feiteng Appliance Co.,Ltd.	—
	-manufacturer's model or type reference :	W2H-125 2F	—
	-rated voltage (V) :	400	—
	-rated current (A)..... :	16	—
	-rated breaking capacity (kA)..... :	100	—
	SCPD protective short-circuit		P
	-test voltage (V) :	430	—
	-r.m.s test current (kA) :	102	—
	-power factor :	0.18	—
	SCPD protective short-circuit withstand		P

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
	-max. let-through current (kA).....:	3.544	—
	-joule integral $i^2 dt$ (kA ² s).....:	14.19	—
	SCPD protective short-circuit making		P
	-max. let-through current (kA).....:	3.473	—
	-joule integral $i^2 dt$ (kA ² s).....:	10.41	—
	Behaviour of the equipment during the test		P
9.3.4.3 c)	Conditions of the equipment after the test		P
9.3.3.4	Dielectric verification		P
	test voltage (2 x Ue) for 1min (V) (min.1000V)	1000	—
	No breakdown or flashover		P
9.3.3.4	Leakage current		N/A
	test voltage (1,1 x Ue) (V)		—
	Leakage current ≤ 2 mA / pole		N/A
9.3.3.3 of Part 1	Temperature-rise verification		P
	-conductor cross-section (mm ²)	50	—
	-test current Ie (A)	125	—
	Temperature-rise of main circuit terminals Max. K	19	P

	TEST SEQUENCE IV: ENVIROMENTAL TESTS		
9.5	Electromagnetic compatibility		P
9.5.1	General		—
	Product is classified to be used in environment.....:	B	P
9.5.2	Immunity tests		—
	Test / Generic Standard	Level	
9.5.2.2	Electrostatic discharge immunity test/ IEC 61000-4-2	8 kV / air discharge 4 kV / contact discharge	P

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.5.2.3	Conducted radio-frequency immunity test IEC 61000-4-6	10 V _{rms} / 150 kHz to 80 MHz	P
	Radiated radio-frequency electromagnetic field immunity test/ IEC 61000-4-3	10 V/m / 80 MHz to 1 GHz	P
9.5.2.4	Electrical fast transient/burst immunity test/ IEC 61000-4-4	2 kV on power ports 1 kV on signal ports	P
9.5.2.5	1,2/50 μ s – 8/20 μ s surge immunity test/ IEC 61000-4-5	2 kV (line to earth) 1 kV (line to line)	P
9.5.2.7	Voltage dips and interruptions immunity test IEC 61000-4-11	30 % reduction for 0,5 cycle 60 % reduction for 5 and 50 cycles 100 % reduction for 250 cycles	N/A
9.5.3	Emissions tests		—
9.5.3.1	General		—
9.5.3.2	Conducted radiofrequency emission tests		—
	The product does not exceed the limits specified in the standard CISPR 11 for the appropriate environment indicated in clause 8.3.1.		P
9.5.3.3	Radiated radiofrequency emission tests		—
	The product does not exceed the limits specified in the standard CISPR 11 for the appropriate environment indicated in clause 8.3.1.		P

EN 60 947-6-1

Clause	Requirement + Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

9.3.3.2.6 **TABLE 3: Transfer on availability of alternative voltage or voltage-frequency**

TABLE 3: Transfer on availability of alternative voltage or voltage-frequency																16			
Ambient (°C)																			
Specified accuracy (U): %																			
Specified accuracy (f): %																			
Test case																			
Test	Sensing 1), 2)	Rated phase voltage V	Rated Frequency Hz	Threshold %	Ts s	Number of phases	N connection Yes/No	Limit value V/Hz	Tested phases L1/L2/L 3	Reference value				ATS measurement errors				Verdict	
										L1	L2	L3	f	L1	L2	L3	f		
No											V	V	V	Hz	%	%	%	%	
									</										

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict

TABLE 5: Operation on loss of supply voltage

[illegible]

Supplementary information:

CTT: Contact Transfer Time ($1 - II/II - I$)

TOT: Total operating time (including Ts)

Verdict	
---------	--

[illegible]

--

1)	60947-6-1, 9.3.3.2.6 b) 1)
2)	60947-6-1, 9.3.3.2.6 b) 2)

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict

Table 4: Temperature-rise test

Test sample: #01		Ith/Ithe: 125A		Verdict
Test voltage (V):		Ambient temperature (°C) 17		P
Thermocouple Locations		Phase	Measured dT (K)	Max. temperature limit dT (K)
Terminals/in		L1	14	70
		L2	16	70
		L3	15	70
		N	14	70
Terminals/out		L1	14	70
		L2	18	70
		L3	14	70
		N	13	70
Enclosure		/	10	50
Components	Operation handle	/	2	25

Test arrangements for temperature-rise test.

EN 60 947-6-1			
Clause	Requirement + Test	Result - Remark	Verdict

Table 8: Temperature-rise test

Table 8: Temperature-rise test				
Test sample #04		lth/lthe 125A		Verdict
Test voltage (V)		Ambient temperature (⁰ C) 17		P
Thermocouple Locations		Phase	Measured dT (K)	Max. temperature limit dT (K)
Terminals/in		L1	14	70
		N	13	
Terminals/out		L1	15	70
		N	14	
Enclosure			7	50
Components	Operation handle	/	1	25

Test arrangements for temperature-rise test.